

Electrical Safety Recall

Saber 7.5KVA / 7500W Generator (SGEN7500ECO)

Sold at Total Tools stores from 1st October 2013

&

Detroit 7.5KVA / 13hp Generator (YW800HECO)

Detroit 3.1KVA / 2500W Generator (DFD3000HS2)

Sold at Total Tools stores from 1st April 2013

Defect - Manufactured with a Multiple Earth Neutral (MEN) link between neutral & earth without a Residual Current Device (RCD). Not compliant with AS2790: 6.1.9. The Saber (SGEN7500ECO) also has a CBE (Circuit Breaker for Equipment) switch that is single pole and is not compliant with AS2790: 6.1.4

Hazard - If a fault occurs in the unit or equipment there is the possibility of an electric shock.

What to do - Cease using the product immediately and return it to the Total Tools store where purchased for modification.

Further Information

Total Tools

Unit 5B, 730 Lorimer Street

Port Melbourne VIC 3207

Tel: (03) 9261 1910



See www.recalls.gov.au for
Australian Product Recall Information